



# Texas Commission on Environmental Quality

*Protecting Texas by Reducing and Preventing Pollution*

## CERTIFICATE OF DELIVERY OF PUBLIC NOTICE TO CUSTOMERS

Public Water System (PWS) name: CITY OF THROCKMORTON  
PWS ID (7-digit number required): TX2240001  
Type violation: TTHM MCL, LRAA  
Time Period of violation: third quarter of 2020

The PWS named above has distributed the Public Notice (PN) for the type of violation and time period listed above by:

**Mail or direct delivery, to bill-paying customers as required by 30 TAC §290.122(b)(2)(A) for community water systems; and**

The information contained in this public notification is correct and complies with required public notification content in accordance with 30 TAC §290.122 and;

Made an adequate good-faith effort to reach non-bill-paying consumers by appropriate methods (check all below that apply):

- Posting the PN on the internet at www.throckmorton.tx.org/public-notice.html
- Mailing the PN to postal patrons within the service area that do not receive a bill
- Advertising the PN in news media
- Publication of PN in local newspaper
- Posting the PN in public places
- Delivery of multiple copies to single bill addresses serving several persons
- Delivery to community organizations
- Email notification

Date of Delivery to Customers 10/26/2020

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

Certified by:	Name (print): <u>Jimmy Collins</u>	Title: <u>City Supervisor</u>
	Phone: <u>940-849-4411</u>	
	Signature: <u>Joyfaller</u>	Date Signed: <u>10/26/2020</u>

Mail a copy of this completed form and a copy of the Public Notice that was delivered to your customer to:

**TCEQ - Drinking Water Inventory & Protection Team**  
**Attn: Public Notice (MC-155)**  
P. O. Box 13087  
Austin, TX 78711-3087

**Mandatory Language for a Maximum Contaminant Level Violation  
MCL, LRAA / TTHM**

The Texas Commission on Environmental Quality (TCEQ) has notified the CITY OF THROCKMORTON TX2240001 that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total trihalomethanes. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total trihalomethanes to be 0.080 milligrams per liter (mg/L) based on locational running annual average (LRAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total trihalomethanes indicates a compliance value in quarter three 2020 of 0.096 mg/L for DBP2-01.

Trihalomethanes are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:

We have been working on flushing the lines to  
clean the water every week. Also we are in the  
process of cleaning water lines in means of a burnout!  
<corrective actions>

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Jimmy Collins at  
940-862-3109.  
<area code + phone number> <water system official's name>

Posted /Delivered on: 10/26/2020  
<Date Posted>

**Instructions for preparing the required Public Notice:**

Recopy the mandatory language above and insert the underlined information in the spaces indicated.

The TCEQ recommends that the public water system provide a copy of the Public Notice(s) to local and state officials, such as Mayors, City Council Members, County Commissioners, Judges, and/or State Representatives, that are located in or that represent the affected area(s) served by the system.

**Public Notice delivery timelines:**

The initial public notice shall be issued as soon as possible, but in no case later than 90 days after the violation was identified. Repeat public notice shall be issued every 90 days for as long as the violation persists. All notifications require the attached Certificate of Delivery due 10 days from the posting date of the above notice.

Refer to 30 TAC §290.122 for additional information on Public Notification.